

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES
			J	1 2
2. AMENDMENT/MODIFICATION NO. 0004	3. EFFECTIVE DATE 01-Jul-2004	4. REQUISITION/PURCHASE REQ. NO. W81D4A-4020-1314		5. PROJECT NO.(If applicable)
6. ISSUED BY CONTRACTING DIVISION 69-A HAGOOD AVE CHARLESTON SC 29403-5107	CODE W912HP	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W912HP-04-R-0002	
		X	9B. DATED (SEE ITEM 11) 28-May-2004	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended.				
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) THE PROSAL DUE DATE IS EXTENDED. PROPOSALS ARE DUE 21JUL 04 AT 2:00 PM EASTERN STANDARD TIME TO THE ADDRESS LISTED IN BLOCK 7 OF THE SF1442 ATTN: HENRY WIGFALL 843-329-8088. SEE CONTINUATION PAGE				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		01-Jul-2004

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

ADDITION TO SPEC. SECT. 15200

The following change shall be made to the specifications:

Section 15200, Page 36, Paragraph 2.21 – Add the following:

Vacuum priming system shall be simplex, designed to provide vacuum priming for the raw water main. The priming system shall be heavily constructed for continuous running duty, including a heavy steel tank, having a minimum 3/16” thick shell and heads including a corrosion allowance of 1/16”. The priming system shall include: dry reciprocating piston or rotary oil seal type vacuum pump(s), motor(s), vacuum switches and priming valves, vacuum gauge, water gauge, vacuum break valve, water level control switch, warning horn or light, magnetic starters with H.O.A. switches and 110V transformer. The priming system shall be a 200 gallon single tank mounted unit, complete with OSHA belt guards, all assembled, wired and pre-tested at the factory, for immediate use in the field. The vacuum pump shall have a rated displacement of 60 cubic feet of air. One automatic priming valve shall be furnished as shown on the plans. The priming valve shall be installed in an 8’ dia. precast manhole as shown on plans and listed in Section 02531, Sanitary Sewers. The priming valves shall be installed in strict accordance with the Manufacturer’s recommendation. The complete system including the priming valves shall be on one manufacturer.

CLARIFICATION TO AMENDMENT 3

The Standard General Conditions for Procurement Contracts pages 00700-1 through 00700-18 are for information only between Contractor(s) and seller of Zenon materials. The Standard General Conditions for Procurement Contracts listed on these pages are not applicable to this solicitation or resultant award.

(End of Summary of Changes)